

स्थापना : १९७०

“गावचा सर्वांगिन विकास हेच ग्रामपंचायतीचे ध्येय ।”



ग्रामपंचायत सोमवार पेठ

ता. पन्हाळा, जि. कोल्हापूर.



- ग्रा.पं. कराची रक्कम मुदतीत भरून सहकार्य करा.
- स्थानिक जन्म मृत्युची नोंद २१ दिवसात ग्रा.पं.कडे करा.
- पाण्याचा अपव्यय टाळा नळांना तोटी बसवा.
- अल्प बचतगट आपलेसाठी व राष्ट्रसाठी



कुटुंब लहान सुख महान

- घर तेथे शौचालय बांधा, कुटुंबाचे आरोग्य राखा.
- कचरा गटारामध्ये टाकू नका. गटारे स्वच्छ राखा.
- घर व परीसर स्वच्छ ठेवा.
- पाण्यात मेडीक्लोअर टाकून पिण्यास पाणी वापरावे.

जावक क्र. : ७९
२२१६१२०२९

दि. २९ / ९



SANITARY CERTIFICATE

The sanitary conditions of the Sanjeevan Public School (CBSE) Somwar- Peth, Panhala, Dist. Kolhapur is found to be satisfactory as per the following descriptions.

- Waste water out let lines are drawn effectively.
- Waste disposal system is arranged properly.
- No stagnation is found anywhere in the campus.
- Drainage system are arranged drawn systematically

The above conditions are inspected by me personally.


Chairman
Sanjeevan Public School




ग्रामसेवक


सरपंच

ग्रामपंचायत सोमवार पेठ
ता. पन्हाळा, जि. कोल्हापूर



सत्यमेव जयते

कनिष्ठ वैज्ञानिक अधिकारी
Junior Scientific Officerजिल्हा सार्वजनिक आरोग्य प्रयोगशाळा, कोल्हापूर
District Public Health Laboratory, Kolhapur

३३०/२ बी, वाय. पी. पोवार नगर चौक, बेंद्रे बिल्डिंग, कोल्हापूर-४१६०१२. ☎ (०२३१) २६५१५८२

330/2 B, Y. P. Powar Nagar Chowk, Bendre Bldg., Kolhapur-416 012.

☎ (0231) 2651582,

Email : ccdphlkop@gmail.com

सार्वजनिक आरोग्य विभाग
महाराष्ट्र शासन

Report on Analysis of Water for Drinking purposes

No. DPHL KR/W-254/03/ 715 /2021

Date: 30 / 03/2021

SAMPLE DATA		
Sample Of: RO Water	Source address: Holywood Academy Sanjeevan School Somwar Peth Panhala	
Container details : Plastic Bottle	Letter details : Date 23/03/2021	
Collected on : 23/03/2021	Received at lab on : 23/03/2021	Testing completed on : 26/03/2021
Sender details: Holywood Academy Sanjeevan School Somwar Peth Panhala		
Std. Reference- Amendment no.1 June 2015 DRINKING WATER - SPECIFICATION		

TEST DATA						
Sr. No	Parameter	Result	Unit	As per IS 10500:2012		Method
				Acceptable Limit	Permissible Limit	
Oganoleptic and Physical Parameter						
1	Physical appearance	Clear	--	--	--	APHA Ed.22 nd (2012)
2	Odour	Agreeable	--	Agreeable	Agreeable	
3	pH	6.52	--	6.5 - 8.5	No Relaxation	
4	Turbidity	0.98	NTU	1.0	5.0	
5	Total Dissolved Solid	170.0	mg/litre	500.0	2000.0	
General parameter concerning substances undesirable in excessive amount						
6	Chloride (as Cl)	55.77	mg/litre	250.0	1000.0	APHA Ed.22 nd (2012)
7	Fluoride (as F)	Not Detected	mg/litre	1.00	1.50	
8	Iron (as Fe)	0.022	mg/litre	1.0	No Relaxation	
9	Nitrate (as NO ₃)	0.62	mg/litre	45.0	No Relaxation	
10	Total Alkalinity (as CaCO ₃)	14.95	mg/litre	200.0	600.0	
11	Total Hardness (as CaCO ₃)	110.8	mg/litre	200.0	600.0	
END OF TEST RESULT						

OPINIONS and REMARKS

- ❖ The sample is not collected by laboratory
- ❖ Analysis results pertain only to 'as received' sample and without prejudice to its source/process.
- ❖ The sample is potable and chemically fit for drinking purpose on the basis of analysed parameter only. However can be used for drinking purpose only after proper treatment, disinfection and ascertaining its bacteriological quality frequently or regularly
- ❖ विश्लेषण घटक आधारावर रासायनिक दृष्ट्या सदर नमुना पिण्यास योग्य असून, योग्य प्रक्रिया वा निर्जंतुकीकरण करून अणुजीवीय विश्लेषणांती पिण्यास योग्य असल्याची खात्री झाल्यानंतरच पाणी पिण्यासाठी वापरवे.

----- END OF OPINIONS and REMARKS -----

Shinde
Junior Scientific Officer
Dist Public Health Laboratory
Kolhapur-416 005



सत्यमेव जयते

कनिष्ठ वैज्ञानिक अधिकारी
Junior Scientific Officer

जिल्हा सार्वजनिक आरोग्य प्रयोगशाळा, कोल्हापूर
District Public Health Laboratory, Kolhapur

३३०/२ बी, वाय. पी. पोवार नगर चौक, बेंद्रे बिल्डिंग, कोल्हापूर-४१६०१२. ☎ (०२३१) २६५१५८२
330/2 B, Y. P. Powar Nagar Chowk, Bendre Bldg., Kolhapur-416 012.
☎ (0231) 2651582, Email : ccdphlkop@gmail.com



सार्वजनिक आरोग्य विभाग
महाराष्ट्र शासन

Report on Bacteriological Analysis of Water

No. DPHL KR/Pvt-67/769/03/2021

Date: 06/04/2021

SAMPLE DATA			
Samples of: आर.ओ. पाणी	Senderdetails:- होलीवुड academy संजीवनस्कूल,सोमवार पेठ पन्हाळा		
Container details : Glass bottle	Letter details: --, .24.03.2021.		
Collectedon:24.03.2021	Received at lab /Analysis on:24 .03.2021	Testing completed on:30.03.2021	
(Standard Reference: IS:10500:2012, Drinking Water – Specification)			


TEST DATA			
Sr. No.	Organism	Result	Requirement
1	Total Coliforms /100 ml	Not detected	Should not be detectable in 100 ml
2	Thermotolerant coliforms /100 ml	Not detected	Should not be detectable in 100 ml
3	E.Coli / 100 ml	Not detected	Should not be detectable in 100 ml
END OF TEST RESULT			

REMARKS and OPINIONS:

- ❖ Sample is not collected by laboratory.
- ❖ It is presume that representative sample send for analysis and results pertain only to 'as received' and without prejudice to its source/process.
- ❖ Sample is potable and fit for drinking purposes on the basis of organism tested.
- ❖ सदर पाणी नमुना अणुजीवीय दृष्ट्या पिण्यास योग्य आहे

----- END OF OPINIONS and REMARKS -----


Chairman
Sanjeevan Public School


Junior Scientific Officer
District Public Health Laboratory, Kolhapur